



DEVIATION REQUEST FORM			
Title:	Pre-Qualification (PQ) Documents for M/s. HILLPOINT, Qatar	MAS Reference:	N/A
Date:	04/04/2019	PQ Reference:	SC-C04-CAG-ABL-PSS-AD-00443 Revision 6

PM REMARKS

In accordance with SC letter Ref: SC-C04-CAG-LET-QSC-AEC-17-00164, dated 16th October 2017 regarding Delegation of Authority and Vendor Pre-qualification Process letter Ref: SC-C04-CAG-LET-QSC-AEC-17-00167, dated 16th November 2017.

The Engineer's Representative shall have the authority to perform the aforementioned duties for all works, except for specific packages, for which the Engineer's Representative shall obtain the Engineer's final approval.

- Any items (Mock-Ups, samples, materials and Contractor proposals) related to permanent and visible finishes for Stadium, Precinct and Energy Centre.
- Selection of alternative materials, specifications, suppliers, and vendor for Stadium, Precinct and Energy Centre.
- Selection of major and/or critical Equipment for Stadium, Precinct and Energy Centre.
- Selection of any ICT integrated system for Stadium, Precinct and Energy Centre.
- The Engineer's Representative shall not reject nor approve newly proposed Sub-Contractor's Vendors or suppliers not listed in the PVL without obtaining the Engineer's Approval.
- Other (See below for details)

Notes

The Contractor has submitted a PQ of **M/s. HILLPOINT QATAR** for:

- 1) Supply & Installation of Gypsum Board Partition & Cladding Works at Stadium; and
- 2) Gypsum & Metal Ceiling Works in Energy Centre.

Proposed scope includes the following:


- a) Gypsum board partitions and linings, in the Stadium, manufactured by Saint Gobain (Turkey).
- b) Gypsum board at the Stadium external staircase (IWSS 213) - internal side - manufactured by USG Boral (Oman).
- c) Cement board parapet cladding (above Level 5 parapet of the Stadium), manufactured by M/s Everest Industries (India), also, M/s. Everest Industries has a local dealer M/s. Al Amodi Group;
- d) Cement board at Stadium external steel staircase (IWSS 213) – external side – manufactured by USG Boral (USA).
- e) Gypsum and metal and metal ceilings manufactured by Saint Gobain (Turkey).

Gypsum Boards - partitions: Contractor proposed M/s Saint Gobain - Turkey, whereas, British Gypsum (Saint Gobain products), UK is specified on the Vendor's list (refer to code 092116).

As for the two (2) hour fire rated gypsum boards partitions, the Contractor's reasons for proposing USG Boral (Oman) (not specified in the Vendors List) is that "M/s.Knauff doesn't have QCDD certificate for any country of origin".

PM has no objection to **M/s. HILLPOINT, Qatar** and seeks the Engineer's approval, if the Engineer has no objection to above noted comments.



ENGINEER'S APPROVAL/DISAPPROVAL		
Approved: <input checked="" type="checkbox"/>	Disapproval: <input type="checkbox"/>	Remarks / Further Information Required:
Name: Eng. Jassim Telefat		Signature: 
Designation: Competition Venues Executive Director - Group B		Date: 10-04-2019

