




Form:FM1/ES-AB-DP-045
Ver: 5, D: 23/03/2016

OOREDOO
BUILDING & SUPPORT SERVICES DEPARTMENT



Date:19/10/2016	MATERIAL SUBMITTAL	Submittal No.:ARC/HQ1/23/MC/001
PROJECT TITLE	23 Floor - OG Office Enhancement Project HQ 01	
CONTRACT No.		
CONTRACTOR	AL RIYADH CONTRACTING CO.W.L.L	
SUB CONTRACTOR	HILL POINT BUILDING SOLUTIONS	
OWA METAL CIELINGS 1M X 1M		
B.O.Q Ref.	Bill No:1- Civil& Archit-CEILING WORKS	Specs Ref.Nil
Manufacturer:	OWA CIELING SYSTEMS	Country of Origin:GERMANY
Supplier Name:	HILL POINT BUILDING SOLUTIONS	Agent Name:HILL POINT
Literature:	Attached	Samples:Nil
Fully Complies to Specification : YES / NO	Fully Complies to Design Drawings: YES / NO	Fully Complies to Technical Requirements: YES / NO
In case of Non Compliance to any of the above items contractor to provide details of Non Compliances & Justification. IF not provided the Approval is not Valid		
Contractor Signature:		Stamp:
Architectural Comments:		
* Confirms Acoustic rating NRC-75-90 compliance. [provide additional acoustic in-fill as per recommendations]		Name : _____ Signature: Date : _____
Structural Comments:		
* Provide tech-data sheet for suspension system.		Name : _____
* provide complete sample for Approval.		Signature: _____
* provide the colour code.		Date : _____
Mechanical Comments:		
_____		Name : _____
_____		Signature: _____
_____		Date : _____
Electrical Comments		
_____		Name : _____
_____		Signature: _____
_____		Date : _____
Ooredoo Decision:		
<input checked="" type="checkbox"/>	APPROVED	Date: 19/10/2016 Signature:
<input type="checkbox"/>	APPROVED WITH CONDITIONS	
<input type="checkbox"/>	REJECTED	



19/10/16

cc: 1. Contractor 2. Ooredoo Project Coordinatc 3. Ooredoo Project File